Product Information Sheet

ADVANTAGES

- A broad spectrum antiscalant designed to inhibit inorganic scale formation in membrane separation processes
- Inhibits calcium carbonate scale up to a Calcium Carbonate Nucleation Index (CCNI) of 2.35
- Effectively inhibits formation of calcium sulfate, calcium fluoride, barium sulfate, strontium sulfate, and silica
- Stabilizes metal ions to prevent metal oxides precipitation and disperses existing metal oxides/ hydroxides, silt and clay particles
- Compatible with polyamide membranes from all membrane manufacturers
- Environmentally compatible, especially where discharge of waste into the environment is a concern

TYPICAL PROPERTIES

Appearance White Powder Odor Characteristic Solubility in water Complete

PACKAGING

50 lb. pails and 400 lb. non-returnable plastic drums



SAFETY & HANDLING

Store in a cool, dry place. In accordance with good safety practice, handle with care and avoid contact with eyes and prolonged or repeated contact with skin. For more information, see the Safety Data Sheet provided with this product.

CHEMICAL FEEDING AND CONTROL

Injection:

Megaflux® GA should be injected continuously into the RO feedwater line, always downstream of multimedia filters, and preferably downstream of the cartridge filters in the presence of a static mixer. In the absence of a static mixer, dosing upstream of the cartridge filters will serve as a substitute to improve mixing.

Dosing:

The dosage required to inhibit scale formation will typically be in the range of 1-5 ppm, depending on feed water quality and system operating parameters. Dosage can be determined using Proton® membrane antiscalant projection software, or can be provided by an AWC technical representative.

Dilution:

Megaflux® GA must be dissolved prior to use. For product preparation, always use water that is free of any chlorine or detectable hardness — deionized water or RO permeate are preferred due to their higher purity, but softened water is also acceptable. To prepare, dissolve 100 grams of Megaflux® GA in 1 liter of water. This product contains a preservative to prevent biological growth in the feed tank. Dilution in excess of recommendation will impact the potency of the preservative. If dilution beyond recommendation is unavoidable, it is recommended to replace the diluted



product frequently, preferably every 7 – 10 days.